

UBICACIÓN.-

X: 704729.0

Y: 9973664.2

AV. RODRIGO LEON PESANTEZ

PARQUE JELEN TENKA

AV. LAS DELICIAS

NORTE

RESUMEN	
* TABLERO CONCENTRADOR DE MEDIDORES (12U)	1u
* MEDIDOR ELECTRONICO TIPO PREPAGO 220V	7u
* ACOMETIDA ELECTRICA 2x6 (6)ITU (ENTRADA Y SALIDA DE MEDIDORES)	204m
* CANDADOS LLAVE UNICA	1u

POZOS	E	N
Pr1	704767.5	9973625.1
Pr2	704770.6	9973662.5
Pr3	704770.8	9973668.3
Pr4	704760.7	9973669.1
Pr5	704760.8	9973666.9
Pr6	704759.8	9973659.0

The diagram shows a rectangular control panel with various components and dimensions:

- Dimensions:**
 - Total width: 1.80
 - Top horizontal segments: 0.10, 0.40, 1.26
 - Bottom horizontal segments: 0.06, 0.25, 0.05
 - Left vertical segment: 0.10
 - Main body height: 1.65
 - Base height: 0.30
 - Internal vertical segment: 0.10
 - Panel width segments: 0.05, 0.40, 0.06
- Components and Labels:**
 - REJILLA VENTILACION:** Points to ventilation grilles on the left and right sides.
 - CERRADURA TRIANGULAR:** Points to a triangular lock mechanism on the right side.
 - ARGOLLAS CANDADO:** Points to locking rings in the center section.
 - ENCLAVAMIENTO MECANICO INTERNO:** Points to internal mechanical interlocking mechanisms in the center section.
 - S, M, D:** Labels for different sections or modules within the panel.
 - BASE / MOCHETA:** The base plate at the bottom of the panel.

TABLERO	E	N	DESCRIPCION
TM1	704757.4	9973659.6	TABLERO MEDIDORES

SIMBOLOGIA	
Prn	POZO DE REVISIÓN MV 60x60x80cm, TIPO A
	RED SOTERRADA DE BAJO VOLTAJE 3(2x1/0)+(2x1/0) - TTU Cu
TMn	TABLERO DE MEDICIÓN GENERAL (12U), EN ACERO INOXIDABLE
3P75T	TRANSFORMADOR TRIFÁSICO DE 75 kVA, PADMOUNTED TIPO MALLA
	PUESTA A TIERRA



SELLOS DE APROBACIÓN		PROYECTO ELÉCTRICO "TERMINAL INTERPARROQUIAL RURAL DE SANTO DOMINGO" MEDICION ELÉCTRICA	
 Libro electrónico de firmas JIMMY EDUARDO RAMÍREZ RAMÍREZ	PROYECTO: Libro electrónico de firmas CRISTIAN EDUARDO BORROR CASTILLO ING. CRISTIAN BORROR CASTILLO Reg. 629-F-2015		FECHA: JULIO-2026 SUBESTACIÓN: Pambilles ESCALA: 1: 500
FINANCIAMIENTO: GAD MSD	REVISADO POR: Ing. Jimmy Ramirez	PROYECTO No.: 221-PART-2026 CIRCUITO: Pto XII HOJA: M1 DE M1	